





# CASL Applications and Validation

Andrew Godfrey, ORNL  
AMA Deputy Lead

VERA Workshop  
February 11, 2019



# Advanced Modeling Applications



*“AMA will work closely with the nuclear industry and provide compelling demonstrations of VERA capabilities and workflows.”*

*– Jess Gehin,  
former Director*




From the VERA beginning, CASL has maintained a subset of staff devoted to meaningful applications and testing of VERA

# Advanced Modeling Applications

## Objectives and Strategies

- Apply VERA to relevant industry problems and demonstrate compelling value for the commercial nuclear power industry
- Provide requirements, priorities, user testing, validation, and benchmarking for VERA from nuclear industry perspective
- Staff composed of industry analysts

Watts Bar 2  
Startup Power  
Distribution



## Requirements Drivers

- Reactor Benchmarking
- Challenge Problems
- Test Stand Support
- Industry Engagement
- Code testing and feedback


## Outcomes and Impact

- Significant value demonstrations
- Collaboration with the nuclear industry
- Obtain data, develop models, generate customer base, facilitate VERA deployment
- Successful testing of Challenge Problem capabilities (CRUD, RIA, PCI, Excore)

# AMA in 2019


- \$5M funding
- 30 staff members
  - 57% industry
  - 30% laboratory
  - 3% university
  - 10% consultants
- ~80 milestones
- Maintaining 21 reactor models
  - >150 fuel cycles

CASL is investing heavily in industry now to ensure long-term success of VERA



# VERA Validation Plan

- Power Plant Benchmarking
  - Next slide
- Critical Experiments
  - B&W, Kritz, Dimple, SPERT
- Fuel Rod PIE
  - TMI Cycle 10
  - Catawba MOX LTAs
  - CRUD Scrapes
- Comparisons with CE Monte Carlo Codes
  - MCNP, KENO, Serpent, MC21, etc.




# Power Plant Models

	Plants	Cycles	Reactor and Fuel Type
1	AP1000	1-5	W Gen III+ 2-loop 17x17 XL
2	Byron 1	17-21	W 4-loop 17x17
3	Callaway	1-12	W 4-loop 17x17
4	Catawba 1	1-9	W 4-loop 17x17
5	Catawba 2	8-22	W 4-loop 17x17
6	Davis-Besse	12-15	B&W 15x15
7	Farley	23-27	W 3-loop 17x17
8	Haiyang	1	W Gen III+ 2-loop 17x17 XL
9	Krško	1-3,24-28	W 2-loop 16x16
10	NuScale	1-8	SMR
11	Oconee 3	25-30	B&W 15x15
12	Palo Verde 2	1-16	CE System 80 16x16
13	Sanmen	1	W Gen III+ 2-loop 17x17 XL
14	Seabrook	1-5	W 4-loop 17x17
15	Shearon Harris	Surrogate	W 3-loop 17x17
16	South Texas 2	1-8	W 4-loop 17x17 XL
17	TMI	1-10	B&W 15x15
18	V.C. Summer	17-24	W 3-loop 17x17
19	Vogtle 1	7-15	W 4-loop 17x17
20	Watts Bar 1	1-18	W 4-loop 17x17
21	Watts Bar 2	1-2	W 4-loop 17x17


# Watts Bar Unit 1 Cycles 1-15 Benchmark

195 in-core flux maps


- RCCA bank worths =  $-0.2 \pm 2.0\%$
- Isothermal temperature coeffs =  $-1.4 \pm 0.7$  pcm/F
- Critical boron concentrations =  $-9 \pm 17$  ppm
- In-core power distributions = 1.6% radial, 3.4% total, 0.2% AO





critical boron comparisons



bank worths



# Watts Bar 1 Cycle 7 - CIPS Calculations




- MAMBA not-predictive at the time but potential benefits are clear
  - ~50% improvement in power distribution comparisons
  - Cycle 7 flux map results are as good as non-CIPS cycles
  - Up to 40% improvement in 1<sup>st</sup> half of Cycle 8 as well




# CIPS Risk Assessment for Catawba 2

- VERA analysis of 3 candidate core designs which had already been screened for CIPS with industrial methods
- Duke selected most conservative design
- VERA results showed increased risk of power shift and loss shutdown margin was likely insignificant
- Most cost effective pattern was:
  - 0.3% difference in axial offset
  - 51 pcm in shutdown margin loss
  - **\$250,000 in fuel savings** (\$125K-\$425K)
- In FY18, performing CILC risk assessment for Oconee 3



*Heterogeneous Boron Deposition in VERA (left) vs. typical industrial method (below)*




*“If we would have had this information for cycle 22 we may have chosen differently”*

Scott Thomas

Manager Safety Applications  
Duke Energy


VERA advanced capabilities have potential to reduce the fuel costs of the nuclear industry

# Watts Bar Unit 2 Startup Analysis




Watts Bar 2 transient Xenon-135 distribution at 28% power level

- 4,130 hourly statepoints
- 13.5 days of runtime on 2,784 cores
- 892,837 core-hours
- 16,605 fully-coupled neutronics/TH iterations



Measured Power Distribution Differences




Vanadium Wire Currents =  $0.7 \pm 2.4\%$

Initial Critical Boron Concentration Difference (ppmB)	<b>-2</b>
Isothermal Temperature Coefficient Difference (pcm/°F)	<b>-0.8</b>
Average Control Bank Worth Error (%)	<b>0.7</b>

<https://www.casl.gov/sites/default/files/docs/CASL-U-2017-1306-000.pdf>


# WBN2 VERA vs. Online Monitor



## VERA

All Wire Currents =  $0.7 \pm 2.4\%$

Long Wire Currents =  $0.3 \pm 2.3\%$





## Online Core Monitor

All Wire Currents =  $-0.1 \pm 3.4\%$

Long Wire Currents =  $0.4 \pm 3.1\%$




# AP1000® PWR Advanced First Core



VERA high-fidelity modeling capabilities extended to advanced first core

- Extensive applications by Westinghouse to confirm current predictions for the startup of Sanmen and Haiyang Nuclear Plants
- Measurements from these startups will be available later this year

# B&W 1810 Critical Experiments



- Critical Experiments Run in early 1980's
- Main purpose was to test Gadolinia, but also tested other absorbers and two different enrichments
- Limited pin-by-pin measurements

# B&W 1810 Results

Core	CASMO	47g	51g	51g P2
1	83.0	-358.3	39.1	205.8
2	27.0	-340.3	39.5	193.0
3	47.0	-377.6	-7.3	142.4
4	106.0	-265.1	93.9	238.5
5	18.0	-402.1	-41.2	103.1
5A	8.0	-410.3	-53.1	89.7
5B	25.0	-396.6	-35.5	109.2
6	37.0	-340.3	13.0	155.2
6A	31.0	-341.7	6.7	146.8
7	19.0	-398.7	-38.0	106.5
8	28.0	-385.2	-33.5	108.1
9	15.0	-362.8	-16.4	125.0
10	10.0	-404.2	-52.9	87.5
12	114.0	-313.2	50.5	253.3
13	156.0	-273.0	80.9	228.9
14	84.0	-324.9	11.9	178.8
15	140.0	-275.9	59.5	195.3
16	81.0	-322.5	7.9	168.2
17	98.0	-312.0	19.4	154.2
18	268.0	-170.2	181.7	371.0
19	235.0	-188.1	148.9	318.7
20	214.0	-197.9	127.8	283.6
Average	83.8	-325.5	27.4	180.1
Stdev	76.9	71.6	66.1	76.8
Minimum	8.0	-410.3	-53.1	87.5
Maximum	268.0	-170.2	181.7	371.0

$$\Delta k = (k_{\text{eff}} - 1) \times 10^5 \text{ pcm}$$

- Very good agreement
- Compare well to industry standard codes
- Within +/- 200 pcm target

## Pin Power RMS (%)

Core	MPACT (%)	CASMO (%)	KARMA (%)
1	0.48	0.51	0.60
5	0.50	0.57	0.68
12	0.69	0.69	0.71
14	0.79	0.79	0.82
18	1.09	0.86	0.96
20	1.23	n/a	1.12


# Krško Radial Core Power Distribution

$\Delta k = 15$  pcm


RMS = 0.22%

Max = -0.86%


2D Core Comparison of VERA to CE Monte Carlo results at BOC HZP




# Radial Reflector Modeling



*W 4-loop truncated geometry*



*W 2-loop truncated geometry*



*AP1000 full geometry*



# NNL Benchmark against MC21

- Single assembly at BOC HFP (Problem 6)
- Reference solution is KAPL's MC21 coupled with COBRA-IE and COBRA-TF

	1.0373	1.0372		1.0354	1.0323		1.0122	0.9768	
	1.0373	1.0374		1.0356	1.0321		1.0116	0.9767	
	1.0354	1.0363		1.0344	1.0313		1.0110	0.9762	
1.0373	1.0098	1.0099	1.0372	1.0085	1.0056	1.0259	0.9880	0.9725	
1.0374	1.0097	1.0098	1.0372	1.0087	1.0056	1.0261	0.9880	0.9726	
1.0354	1.0099	1.0107	1.0366	1.0086	1.0061	1.0249	0.9889	0.9725	
1.0372	1.0100	1.0106	1.0387	1.0112	1.0086	1.0275	0.9880	0.9718	
1.0373	1.0096	1.0102	1.0389	1.0110	1.0086	1.0276	0.9880	0.9719	
1.0363	1.0107	1.0105	1.0373	1.0113	1.0096	1.0269	0.9892	0.9724	
	1.0373	1.0388		1.0448	1.0450		1.0114	0.9740	
	1.0372	1.0388		1.0448	1.0451		1.0115	0.9741	
	1.0366	1.0372		1.0438	1.0436		1.0116	0.9741	
1.0354	1.0085	1.0112	1.0450	1.0318	1.0512	1.0362	0.9832	0.9649	
1.0355	1.0086	1.0111	1.0449	1.0319	1.0513	1.0361	0.9830	0.9648	
1.0344	1.0085	1.0113	1.0438	1.0336	1.0517	1.0365	0.9834	0.9654	
1.0324	1.0056	1.0085	1.0451	1.0511		1.0173	0.9647	0.9553	
1.0322	1.0057	1.0086	1.0452	1.0513		1.0173	0.9647	0.9553	
1.0313	1.0060	1.0096	1.0436	1.0517		1.0170	0.9636	0.9556	
	1.0262	1.0275		1.0361	1.0174	0.9732	0.9479	0.9462	
	1.0264	1.0278		1.0361	1.0172	0.9734	0.9478	0.9462	
	1.0248	1.0269		1.0365	1.0170	0.9737	0.9487	0.9467	
1.0120	0.9880	0.9882	1.0116	0.9832	0.9645	0.9479	0.9385	0.9421	
1.0119	0.9882	0.9880	1.0116	0.9830	0.9646	0.9481	0.9388	0.9420	
1.0110	0.9889	0.9892	1.0116	0.9834	0.9636	0.9487	0.9400	0.9430	
0.9768	0.9725	0.9719	0.9741	0.9650	0.9555	0.9463	0.9423	0.9479	
0.9769	0.9726	0.9720	0.9742	0.9647	0.9554	0.9462	0.9422	0.9480	
0.9762	0.9725	0.9724	0.9741	0.9654	0.9556	0.9467	0.9430	0.9487	

Radial Pin Powers




$\Delta k = -63$  pcm

RMS = 0.09%

Max = -0.19%

327.2	328.2	327.2	327.2	328.1	326.9	326.5	326.7	325.0
326.7	329.4	326.8	326.8	329.2	326.6	326.3	327.8	324.7
327.2	328.2	327.2	327.2	328.1	326.9	326.5	326.7	325.0
328.2	328.5	328.2	328.2	328.4	328.0	327.5	326.9	325.0
329.4	329.2	329.3	329.4	329.2	329.1	328.7	327.8	324.7
328.2	328.5	328.2	328.2	328.4	328.0	327.5	326.9	325.0
327.2	328.2	327.2	327.3	328.3	327.0	326.5	326.7	324.9
326.8	329.3	326.9	327.0	329.4	326.9	326.4	327.7	324.8
327.2	328.2	327.2	327.3	328.3	327.1	326.5	326.7	325.0
327.2	328.2	327.3	327.4	328.3	326.9	326.4	326.6	324.8
326.8	329.4	327.0	327.2	329.8	327.1	326.5	327.6	324.7
327.2	328.2	327.3	327.4	328.3	327.0	326.4	326.6	324.8
328.1	328.4	328.3	328.3	327.3	326.7	327.2	326.5	324.6
329.2	329.2	329.4	329.8	327.3	326.9	328.3	327.4	324.4
328.1	328.4	328.3	328.3	327.4	326.7	327.2	326.5	324.6
326.9	328.0	327.0	326.9	326.7	326.3	326.9	326.2	324.3
326.6	329.1	326.9	327.1	326.9	326.3	327.8	327.0	324.1
326.9	328.0	327.1	327.0	326.7	326.4	326.9	326.2	324.3
326.5	327.5	326.5	326.4	327.2	326.9	326.6	325.8	323.9
326.3	328.7	326.4	326.5	328.3	327.8	327.3	326.6	323.8
326.5	327.5	326.5	326.4	327.2	326.9	326.6	325.8	324.0
326.7	326.9	326.7	326.6	326.5	326.2	325.8	325.1	323.3
327.8	327.8	327.7	327.6	327.4	327.0	326.6	326.1	323.4
326.7	326.9	326.7	326.6	326.5	326.2	325.8	325.1	323.4
325.0	325.0	324.9	324.8	324.6	324.3	324.0	323.3	321.9
324.7	324.7	324.8	324.7	324.4	324.1	323.8	323.4	321.1
325.0	325.0	325.0	324.8	324.6	324.3	324.0	323.4	321.9

Exit Coolant Temperatures



RMS = 0.02 °C

Max = ±0.1 °C

D. KELLY III, et al., "MC21 / CTF and VERA Multiphysics Solutions to VERA Core Physics Benchmark Progression Problems 6 and 7," Proc. M&C 2017 - International Conference on Mathematics & Computational Methods Applied to Nuclear Science & Engineering, Jeju, Korea, April 16-20, 2017, on USB (2017)

# NNL HFP Quarter Core Benchmark


- BOC HFP with eq. Xenon and boron search (Problem 7)
- Reference solution is KAPL's MC21 coupled with CTF

1.1179	1.0302	1.1156	1.0564	1.1571	1.0531	1.0487	0.7558	MC21/CTF
1.1177	1.0327	1.1160	1.0591	1.1574	1.0547	1.0454	0.7551	VERA
-0.02%	0.24%	0.04%	0.26%	0.02%	0.15%	-0.32%	-0.09%	% diff (VERA vs. MC21/CTF)
1.0299	1.1081	0.9828	1.1475	1.0795	1.1549	1.0119	0.8558	
1.0327	1.1091	0.9862	1.1490	1.0826	1.1547	1.0122	0.8548	
0.27%	0.10%	0.34%	0.13%	0.29%	-0.01%	0.02%	-0.11%	
1.1148	0.9825	1.1310	1.0740	1.1844	1.1210	1.0552	0.7646	
1.1160	0.9862	1.1328	1.0778	1.1856	1.1225	1.0517	0.7633	
0.10%	0.37%	0.15%	0.36%	0.10%	0.13%	-0.33%	-0.17%	
1.0556	1.1471	1.0740	1.1798	1.0774	1.1184	0.9865	0.6335	
1.0591	1.1490	1.0778	1.1809	1.0799	1.1164	0.9854	0.6322	
0.33%	0.16%	0.35%	0.10%	0.23%	-0.18%	-0.11%	-0.21%	
1.1566	1.0793	1.1850	1.0777	1.2377	0.8650	0.8914		
1.1574	1.0826	1.1856	1.0799	1.2377	0.8639	0.8895		
0.07%	0.31%	0.05%	0.20%	0.00%	-0.12%	-0.21%		
1.0537	1.1557	1.1219	1.1193	0.8654	0.8656	0.6073		
1.0547	1.1547	1.1225	1.1164	0.8639	0.8629	0.6059		
0.10%	-0.08%	0.05%	-0.26%	-0.17%	-0.31%	-0.24%		
1.0492	1.0128	1.0565	0.9876	0.8923	0.6077			
1.0454	1.0122	1.0517	0.9854	0.8895	0.6059			
-0.37%	-0.06%	-0.46%	-0.22%	-0.31%	-0.29%			
0.7563	0.8565	0.7653	0.6343					
0.7551	0.8548	0.7633	0.6313					
-0.16%	-0.19%	-0.27%	-0.47%					

Color Key  
0.600  
0.900  
1.250

330.9	327.4	330.8	328.2	332.1	328.2	328.9	318.5	MC21/CTF (C)
331.0	327.6	330.9	328.4	332.2	328.3	328.8	318.4	VERA (C)
0.1	0.2	0.1	0.2	0.1	0.1	-0.1	-0.1	Difference (C): VERA - MC21/CTF
327.4	330.5	325.9	331.8	329.0	332.2	326.6	321.9	
327.6	330.7	326.1	332.0	329.2	332.2	326.7	321.8	
0.2	0.2	0.2	0.2	0.2	0.0	0.1	-0.1	
330.8	325.9	331.3	328.8	333.0	330.3	329.2	318.7	
330.9	326.1	331.4	329.0	333.1	330.4	329.1	318.7	
0.2	0.2	0.2	0.2	0.1	0.1	-0.1	-0.1	
328.2	331.8	328.8	332.9	329.1	331.0	326.0	314.5	
328.4	332.0	329.0	333.0	329.2	331.0	325.9	314.4	
0.2	0.2	0.2	0.1	0.1	0.0	-0.1	-0.1	
332.1	329.0	333.0	329.1	334.2	322.5	323.0		
332.2	329.2	333.1	329.2	334.2	322.5	322.9		
0.1	0.2	0.1	0.1	0.0	0.0	-0.1		
328.2	332.2	330.3	331.1	322.6	322.1	313.6		
328.3	332.2	330.4	331.0	322.5	322.0	313.5		
0.1	0.0	0.1	-0.1	-0.1	-0.1	-0.1		
328.9	326.7	329.2	326.0	323.1	313.6			
328.8	326.7	329.1	325.9	322.9	313.5			
-0.1	0.0	-0.1	-0.1	-0.2	-0.1			
318.5	321.9	318.8	314.5					
318.4	321.8	318.6	314.4					
-0.1	-0.1	-0.2	-0.1					

Color Key  
313.00  
324.00  
335.00



$\Delta k = <1$  ppmB

Radial Assembly Powers

RMS = 0.22%

Max = -0.47%

$\Delta AO = 0.03\%$

Exit Coolant Temperatures


RMS = 0.13 °C

Max =  $\pm 0.2$  °C



D. KELLY III, et al., "MC21 / CTF and VERA Multiphysics Solutions to VERA Core Physics Benchmark Progression Problems 6 and 7," Proc. M&C 2017 - International Conference on Mathematics & Computational Methods Applied to Nuclear Science & Engineering, Jeju, Korea, April 16-20, 2017, on USB (2017)

# NuScale Test Stand

- NuScale Test Stand completed first phase
  - 8 fuel cycles simulated with VERA
  - Comparisons to licensed industry methods
  - Validation of effects of steel reflector block
  - In-house build of VERA completed in Corvallis
  - VERA training completed in June 2018
- Initial MAMBA-1D application successful in demonstrating multi-physics feedback effects on CRUD generation and boron deposition
- Proprietary report completed and public version available soon




# AP1000 Lattice Depletion Benchmarks




- 37 +/- 23 pcm for 900K over 6 fuel and burnable absorber types
- Good agreement with both Serpent continuous-energy Monte Carlo depletion code
- Good agreement with Westinghouse latest lattice physics methods Paragon-2


# WB1 Excore Transport Demonstrations



Simulation of fluence in the reactor vessel over the full life of Watts Bar Unit 1





Average Fluence Rate By Cycle



# Shearon Harris Downcomer Attenuation

## Smith, Davidson – RPSD 2018

- VERA proven capable of direct excore detector response calculations consistent with industry-grade applications




*Omnibus Model of Harris  
with Fission Source from  
MPACT*

# Initial Neutron Fluence and Iron dpa Results

**Cumulative neutron fluence and total iron dpa in the iron coupon located at the center of the surveillance capsule from cycles 1 to 3**

Parameter (Accumulated from Cycles 1 to 3)	VERA – CADIS (1 $\sigma$ %RE)	*REFERENCE	%Difference
Neutron Fluence ( E > 1.0 MeV) n/cm <sup>3</sup>	$9.78 \times 10^{18}$ (0.8%)	$1.072 \times 10^{19}$	-8.79%
Neutron Fluence ( E > 0.1 MeV) n/cm <sup>3</sup>	$4.68 \times 10^{19}$ (0.2%)	$5.224 \times 10^{11}$	-10.34%
Iron dpa	$1.96 \times 10^{-2}$ (0.3%)	$2.205 \times 10^{-02}$	-10.99%



\*BWXT Services Inc., “Part 1 – Watts Bar Nuclear Plant Unit 1, Reactor Vessel Surveillance Capsule W Test Results & Reactor Vessel Fracture Toughness (J-R) Test Results,” NRC Public Document, ML012900048 (2001).

# Computational Performance


- 50 million particles per state point in Shift with CADIS
- Weight windows generated at first state point and the same VR parameters are used for all the state points
- Neutron-only transport

	MPACT / CTF [min, max, avg]	MPACT / CTF [cores]	Shift [min, max, avg]	Shift [cores]
Cycle 1 run time per state point (minutes)	22.3, 147.3, 68.3	840	1.1, 1.6, 1.2	400
Cycle 2 run time per state point (minutes)	42.6, 195.1, 89.1	915	1.2, 4.4, 1.5	400
Cycle 3 run time per state point (minutes)	21.8, 204.6, 60.3	992	1.2, 1.5, 1.3	400





# Development of Public Reactor Benchmark Specifications

- Public benchmark specs for Cycle 1 released in 2014
- Based on data from Watts Bar and publicly available fuel design data
- Updating in 2019 for:
  - Cycle 2 startup tests and depletion
  - Cycle 3 shuffle and depletion
  - Measured flux maps
- NCSU is developing draft NEA/OECD benchmark specification to be released in 2019




<https://www.casl.gov/sites/default/files/docs/CASL-U-2012-0131-004.pdf>

# Study of HZP SLB DNB Limiting Case






Parameter	High-Flow	Low-Flow
DNB Limiting Elevation (cm)	45.9	30.5
Max. Pin Linear Power (W/cm)	264.3	178.5
Heat Flux (W/m <sup>2</sup> )	801.4	558.7
Equilibrium Quality	-0.047	-0.114
Mass Flux (kg/m <sup>2</sup> /s)	4529.1	466.9



VERA-CS 4-Loop Core Model

- 56,288 channels
- 112,064 gaps
- 50,952 fuel rods, 4,825 GT/IT
- ~60 axial nodes

# AP1000 Rod Ejection at HFP







*Highly skewed axial power initially with partially inserted rod*

- Highly asymmetric power distribution
- High power clustered in and around the ejected rod, and tapers off away from the ejected rod.
- The max. power peaking factor of  $\sim 17.3$  at the peak of the pulse.

# AP1000 Rod Ejection at Part-Power


Additional simulations starting at 5%, 15%, 25%, 50%, and 75% power



- 5% power case appears to be most limiting in VERA results



# Reactivity Insertion Accident with VERA

- Fully coupled neutronics/thermal-hydraulics transient solution
- Internal simplified fuel rod model with dynamic gap
- Existing commercial Westinghouse 4-loop core design at End-of-Cycle
- Conservatism on Beta
- Initiated from HZP conditions – core power reached 904% FP with \$1.5 ejected rod worth
- 6480 cores in 36 hours



# Subcritical, Source-Driven Application

- Subcritical, source-driven problem to simulate excore detector response during core refueling
- Neutron sources from burned fuel (ORIGEN) and activated secondary source rods (Sb-Be)
  - Photoneutron reaction correlation developed with ORIGEN and MCNP
- MPACT pin-wise diffusion used for subcritical multiplication
- Shift hybrid MC transport used for source-range detector response





Subcritical thermal neutron flux in WB1C8 when fully loaded, including secondary neutron sources (log scale)

# Ex-Core Detector Response Benchmark

- VERA used to predict detector response outside of the pressure vessel in Watts Bar Unit 1
- Relative comparisons to measured source range detector signals
- Excellent agreement between calculations and measurements: - **0.3±3.9%** over ~17,000 measured points averaged over 140 total intervals (8 fuel cycles)
- Report available soon for public release

State-of-the-Art Capability for Coupled In-Core and Ex-Core Neutron Transport Analyses

Adjoint Flux for Source Range Detectors





[www.casl.gov](http://www.casl.gov)